

**Drinking Water Quality and Compliance
Regina North Industrial Subdivision
2017 Notification to Consumers**

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the Regina North Industrial Subdivision water quality and sample submission compliance record for the January 1, 2017 to December 31, 2017 time period. This report was completed on August 24, 2018. Readers should refer to the WSA's Municipal Drinking Water Quality Monitoring Guidelines, October 2012, EPB 202 for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need to know more about drinking water in Saskatchewan, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>.

BACTERIOLOGICAL QUALITY

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# Positive of Regular Submitted
Total Coliform	0 Organisms/100 mL	52	52	0
E. Coli	0 Organisms/100 mL	52	52	0
Background Bacteria	Less than 200/100 mL	52	52	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks.

WATER DISINFECTION

Chlorine Residual in Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit (either/or)	Range (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Free Chlorine	0.1 mg/L	0.12 - 1.62	52	51	51
Total Chlorine	0.5 mg/L	0.36 - 2.36	52	51	

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual **OR** 0.5 mg/L total chlorine residual is required at all times throughout the distribution system. An adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.

Free Chlorine Residual for Water entering the Distribution System

Parameter	Limit (mg/L)	Minimum (mg/L)	# Tests Required	# Tests Performed	% Adequate Chlorine
Free Chlorine	At least 0.1	0.05	Continuous	Continuous	99

Minimum 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering a distribution system. Residuals are monitored continuously and tests are performed on a daily basis by waterworks operators and are recorded in operation records.

TURBIDITY

Turbidity in the Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Limit (NTU)	Range (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No standard	0.19 - 0.93	0	39	0

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is generally reported in Nephelometric Turbidity Units (NTU).

CHEMICAL – TRIHALOMETHANES (THM)

Trihalomethanes are formed when chlorine reacts with organic matter in water. The four THM compounds are: chloroform, dibromochloromethane, bromodichloromethane (BCDM) and bromoform. The sum of the concentrations of these four components is referred to as Total Trihalomethanes. The limit for THM is a long term objective based on an annual average of seasonal samples.

Parameter	Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Trihalomethane	0.100 mg/L	0.134	4	4

More information on water quality and sample submission performance may be obtained from:

RM of Sherwood
4400 Campbell St
P.O. Box 40029 Grasslands PO
Regina SK S4W 0L3